



architects + engineers

538 Broad Hollow Road, 4th Floor East
Melville, NY 11747 | tel 631.756.8000

01.31.19

Dr. Thomas Rogers
Superintendent of Schools
Syosset Central School District
99 Pell Lane
Syosset, NY 11791

**Re: District-Wide Carbon Monoxide Monitoring and Device Inspection
H2M Project No.: SYSD 1827**

Dear Dr. Rogers:

H2M architects + engineers in partnership with J.C. Broderick & Associates, Inc., performed inspections and testing today within each of the 11 school buildings which included all areas at risk of carbon monoxide exposure as defined by the State Education Department and the Building Code. The testing results within each school were all negative for carbon monoxide. Our team has also performed a visual inspection which confirms the District installed carbon monoxide detectors in all areas as required by the code and that each detector is currently active and in working condition.

If you have any questions, please feel free to contact me at 631.756.8000 ext. 1324 or RMarcus@H2M.com.

Very truly yours,
H2M Architects + Engineers

Renee Marcus, AIA, LEED AP
Assistant Vice President | Studio Director

X:\SYSD (Syosset School District)\SYSD1827 - DW CO Detectors\00-Correspondence\19-01-31 CO Detection Letter.docx